

APPENDIX II

RECOMMENDATION	STATUS
<u>CONSTRUCTION PRACTICES</u>	
<p>1. <i>Application of AWWA Standards:</i> COV Waterworks Standard 641 “Emergency Repairs; Disinfection Methods for Watermain Breaks” be adopted for construction and repair work in Stanley Park</p>	Is being included in all work/project documentation
<p>2. <i>Adoption of COV Waterworks Standard 305, Section 2:</i> COV Waterworks Standard 305 be adopted for construction and repair work in Stanley Park.</p>	Included in operational procedures
<p>3. <i>Full Time Inspection:</i> All contract work affecting the drinking water system be inspected full time by a Waterworks staff member.</p>	Current procedure
<p>4. <i>Sampling:</i> Water samples be taken after water main shutdowns that drain the water main.</p>	Current procedure
<p>5. <i>Leak Detection:</i> A regular leak detection program be devised and implemented.</p>	Park Board and City have agreed on program. Implementation scheduled following approval of LOU
<p>6. <i>Force Main Sewer Testing:</i> Further investigation and testing of sewer force mains in the park be carried out.</p>	Same as recommendation 5 above
<p>7. <i>Back Flow:</i></p> <p>a) Irrigation systems in Stanley Park be checked for operational back flow preventers where required.</p>	95% Completed, Remaining to be completed by May 31, 2001
<p>b) All connections to fire hydrants use back flow preventers.</p>	Standard practice
<p>c) Hose bibs in washrooms and external connections be fitted with back flow preventers.</p>	95% Completed, Remaining to be completed by May 31, 2001
<p>d) All facilities within the Park boundaries be inspected for back flow preventers.</p>	95% Completed, balance by May 31, 2001

RECOMMENDATION	STATUS
<p><u>WATER MANAGEMENT</u></p> <ol style="list-style-type: none"> 1. <i>Ensure Chlorine Levels:</i> Work be done to ensure consistently high chlorine levels in the Stanley Park water system, with particular attention to the South West zone. 2. <i>Regular Flushing:</i> A regular flushing program be devised and implemented in Stanley Park. 3. <i>System Flow Characteristics Modeling:</i> A review of the Stanley Park water system flow characteristics be performed, including computer modeling of water residency periods. 4. <i>Sampling Program:</i> For the short term a sampling program was established on August 8, 2000 and will continue for 2 weeks provided negative results for fecal contamination continue. Samples are being taken in duplicate to the GVRD lab and the BCCDC lab. 	<p>Park Board staff continue to monitor 5 sites on a weekly basis.</p> <p>Intermittent flushing being done at present and to be modified after modeling.</p> <p>Modeling is being done by COV Waterworks staff and is nearing completion</p> <p>Bi-weekly testing at 4 locations is being continued.</p>
<p><u>LONG TERM (CAPITAL) PROGRAM</u></p> <ol style="list-style-type: none"> 1. <i>Long Range Plan:</i> A long range plan, similar to the COV Waterworks Long Range Plan be developed for replacement of the Stanley Park water system. 2. <i>System Wide Survey & Documentation:</i> The Stanley Park water system be surveyed for all elements that can be located through currently available technology. 3. <i>Capital Plan Program:</i> A capital Program be developed to implement changes identified by the above review. 	<p>To be undertaken jointly by Park Board and Engineering Services in 2001</p> <p>A partial survey was in place at the time of the incident. This was further updated with info from the incident and has been continuing since.</p> <p>To be formulated as part of (1) as implemented by City Engineering Services</p>